

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 20/04/24

It is certified that an inspection team headed by Dr. M. S. Prasad
 (Name of Officers with designation) from CMD Office, Lucknow
 (Name of Department/ Office) inspected the St. Xavier's School, Ranjeetpur, Chibila, Pratapgarh, U.P.
 (Name & Address of the school) on (date of inspection) and found that the
St. Xavier's School (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of 1 year.

Signature with Seal: [Signature]

Name

Designation

Name & Address of the Office / Department :

To

St. Xavier's School
Ranjeetpur, Chibila, Pratapgarh, U.P.
 (Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Saini
 MANAGER
 ST XAVIER'S SCHOOL
 Ranjeetpur Chibila
 Pratapgarh (U.P.)

[Signature]
 Principal
 St. Xaviers School
 School No.- 71133
 Ranjeetpur Chibila, Pratapgarh



Test Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
Pratapgarh
Address- District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
Sukhpalnagar, Pratapgarh - 230001



Report No:	UPJN(R)/PBH/DL/2094	Issue Date:	23-04-2024	Page No	1-2
Remark					
Contact Person:	Digvijay Singh	Address:	UPJN Pratapgarh	Mob:	9169048466

Customer Details

Office Name and Address	XT. Xaviers School, Ranjeetpur chilbala, near sai datt kutir, Pratapgarh
Ref Letter No & Date	Principal, XT. Xaviers School 18-04-2024

Basic details of sample

District	Pratapgarh	Block	-
Gram Panchayat	-	Village	-
Habitation	-	Location	XT. Xaviers School, Ranjeetpur chilbala, near sai datt kutir, Pratapgarh
Water Source	submersible pump	Sample No.	2094
Quantity of Sample	1 Ltr.	Date of Collection	18-04-2024
Receiving Date	18-04-2024	S. Collector	Suresh kr. Singh
Sample Depositor	Suresh kr. Singh	Sampling Method	As per IS 17614: Part 1 : 2021
Analysis Start Date	19-04-2024	Analysis Completion Date:	19-04-2024

Technical Data of Analysis

1	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	pH	7.09	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity NTU	0.61	1	5	IS 3025 (Part 10):2023
3	TDS mg/L	120	500	2000	IS 3025 (Part 16):2023
4	Fluoride mg/L	0.21	1	1.5	IS 3025 (Part 60):2008
5	Total Hardness mg/L	186	200	600	IS 3025 (Part 21):2019
6	Total Alkalinity mg/L	202	200	600	IS 3025 (Part 23):2023
7	Chloride mg/L	96	250	1000	IS 3025 (Part 32):2019

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Analysed By- *A*
Deputy Technical Manager

nm
Authorized Signatory

Laboratory Contact details

Email- digvijay32.singh@gmail.com

Mob-9169048466



Sai
MANAGER
ST XAVIER'S SCHOOL
Ranjeetpur Chilbala
Pratapgarh (U.P.)


nm
Principal
St. Xaviers School
School No.- 71133
Ranjeetpur Chilbala, Pratapgarh

	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Iron mg/L	0.09	1	No relaxation	IS 3025 (Part 53):2003
2	Nitrate mg/L	3.66	45	No relaxation	APHA 4500-No3UV Screening method 2017
3	Sulphate mg/L	11.67	200	400	IS 3025 (Part 24):1986

Analysed By-

Deputy Technical Manager

Authorized Signatory:



Sansu
MANAGER
ST XAVIER'S SCHOOL
Ranjeetpur Chibila
Pratapgarh (U.P.)

[Signature]
Principal
St. Xaviers School
School No.- 71133
Ranjeetpur Chibila, Pratapgarh